



BRANZ Appraised

Appraisal No.615 [2008]

BRANZ Appraisals

Technical Assessments of products
for building and construction

**BRANZ
APPRAISAL
No. 615 (2008)**

Amended 1 March 2011

**FAST WRAP
BUILDING WRAP**

Paul Industries
PO Box 308
Tauranga

Tel: 07 578 8209
Fax: 07 928 5244

Web: www.paulindustries.co.nz



BRANZ
BRANZ Limited
Private Bag 50 908
Porirua City
New Zealand
Tel: +64 4 237 1170
Fax: +64 4 237 1171
www.branz.co.nz



Product

1.1 Fast Wrap is a synthetic building wrap for use as a wall wrap under wall claddings on timber and steel framed buildings. The product is manufactured from an ultra-violet (UV) light resistant non-woven, spun-bonded polypropylene and is coloured beige.



Scope

2.1 Fast Wrap has been appraised for use as a wall wrap on timber framed buildings within the following scope:

- the scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1 with regards to building height and floor plan area; and,
- with absorbent and non-absorbent wall claddings directly fixed to framing; and,
- with absorbent and non-absorbent wall claddings installed over an 18 mm minimum drained cavity; and,
- with masonry veneer in accordance with NZS 3604; and,
- situated in NZS 3604 Building Wind Zones up to, and including 'Very High'.

2.2 Fast Wrap has been appraised for use as a wall wrap on steel framed buildings within the following scope:

- the scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1 with regards to building height and floor plan area; and,
- with absorbent and non-absorbent wall claddings; and,
- with masonry veneer; and,
- situated in NZS 3604 Building Wind Zones up to, and including 'Very High'.

2.3 Fast Wrap has also been appraised for use on buildings subject to specific weathertightness design. Building designers are responsible for the building design and for the incorporation of Fast Wrap into their design in accordance with the declared properties and the instructions of Paul Industries.

Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, Fast Wrap, if used, designed, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet, or contribute to meeting the following provisions of the NZBC:

Clause B2 DURABILITY: Performance B2.3.1(a), not less than 50 years, B2.3.1(b), 15 years and B2.3.2. Fast Wrap meets these requirements. See Paragraphs 9.1 and 9.2.

Clause E2 EXTERNAL MOISTURE: Performance E2.3.2. When used as part of the cladding system, Fast Wrap will contribute to meeting this requirement. See Paragraphs 12.1 and 12.2.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Fast Wrap meets this requirement and will not present a health hazard to people.

3.2 This is an Appraisal of an **Alternative Solution** in terms of the New Zealand Building Code compliance.

Technical Specification

4.1 Fast Wrap is a beige, UV stabilised, non-woven spun-bonded polypropylene.

4.2 The product is supplied in rolls 1.370 m wide x 36.5 and 73 m long and 2.740 m wide x 18.5 and 36.5 m long. The product is printed with the Fast Wrap logo repeated along the length of the roll. The rolls are wrapped in clear polythene film.

Accessories

4.3 Accessories used with Fast Wrap which are supplied by the installer are:

- Fixings - staples, clouts, screws or proprietary wrap fixings, or other temporary fixings to attach the wall wrap to the framing.
- Building wrap support - 75 mm galvanised mesh or galvanised wire, or vertical cavity battens where required to support the wall wrap in accordance with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.5.

Handling and Storage

5.1 Handling and storage of the product, whether on or off site, is under the control of the installer. The rolls must be protected from damage and weather. They must be stored on end, under cover, in clean, dry conditions and must not be crushed.

Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for Fast Wrap. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

Timber and Steel Framing

7.1 Studs must be provided at maximum 600 mm centres. Dwangs must be fitted flush between the studs at maximum 1200 mm centres.

General

7.2 Fast Wrap is intended for use as an alternative to conventional building papers which are fixed over timber or steel framed walls in order to limit the entry of wind into building cavities, and to act as a secondary barrier to wind-driven rain.

7.3 The material also provides a degree of temporary weather protection during early construction. However, the product will not make the building weathertight and some wetting of the underlying structure is always possible before the building is closed in. Hence, the building must be closed-in and made weatherproof before moisture sensitive materials such as wall or ceiling linings and insulation materials are installed.

7.4 Fast Wrap must not be exposed to the weather or ultra violet light for a total of more than 42 days before being covered by the wall cladding.

7.5 Fast Wrap is suitable for use under wall claddings as a wall wrap as called up in NZBC Acceptable Solution E2/AS1, Table 23 on timber framed buildings including non-absorbent metal based wall claddings such as sidings or metal based weatherboards in direct fixed installations. Fast Wrap is suitable for use under cavity based wall claddings as an absorbent synthetic wall wrap as called up in NZS 2295, Table 2.4 on steel framed buildings. Refer to Table 1.

Table 1: NZBC E2/AS1 Table 23 Requirements

NZBC E2/AS1 Table 23 Wall Wrap Properties	Property Performance Requirement	Actual Property Performance
Absorbency	> 100 g/m ²	Pass
Vapour Resistance	< 7 MN s/g	0.223 MN s/g
Water Resistance	> 20 mm	Pass
pH of Extract	> 6 and < 9	7.15
Shrinkage	< 0.5%	-0.10 % (stretched)
Mechanical	Edge tear and tensile strength	Edge tear (Average): Machine direction = 164 N Cross direction = 97 N Tensile strength (Average): Machine direction = 3.4 kN/m Cross direction = 1.95 kN/m
Air Barrier	Air resistance: > 0.1 MN s/m ³	Average 0.120 MN s/m ³ Fast Wrap is suitable for use as an air barrier.

7.6 In cavity installations where the cavity battens are installed at greater than 450 mm centres, the building wrap must be supported between the battens to prevent the wrap bulging into the cavity space when bulk insulation is installed in the wall frame cavity in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.5.

Stucco Plaster

7.7 Fast Wrap is suitable for use as a non-rigid backing material for stucco plaster in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.3.5.1. The wrap must be supported with 75 mm galvanised mesh or wire at 150 mm centres run across the cavity battens to limit deflection to a maximum of 5 mm in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.3.5.2.

7.8 Fast Wrap may also be used as a slip layer over rigid backings for stucco plaster in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.3.3(b).

Structure

8.1 Fast Wrap is suitable for use in all Building Wind Zones of NZS 3604 up to, and including, 'Very High'.

Durability

9.1 Fast Wrap meets code compliance with NZBC Clause B2.3.1 (a), not less than 50 years for building wraps used where the cladding durability requirement or expected serviceable life is not less than 50 years, e.g. behind masonry veneer, and code compliance with NZBC Clause B2.3.1 (b), 15 years for building wraps used where the cladding durability requirement is 15 years.

Serviceable Life

9.2 Provided it is not exposed to the weather or ultra-violet light for a total of more than 42 days, and provided the exterior cladding is maintained in accordance with the cladding manufacturer's instructions and the cladding remains weather resistant, Fast Wrap is expected to have a serviceable life equal to that of the cladding.

Control of Internal Fire and Smoke Spread

10.1 Fast Wrap has an AS 1530 Part 2 Flammability Index of 4 and meets the requirements of NZBC Acceptable Solution C/AS1 Part 6, Table 6.2 for surface finish requirements for suspended flexible fabrics, and therefore it may be used with no restrictions in all buildings.

Outbreak of Fire

11.1 Fast Wrap must be separated from fireplaces, heating appliances, flues and chimneys in accordance with the requirements of NZBC Acceptable Solution C/AS1 Part 9 for the protection of combustible materials.

External Moisture

12.1 Fast Wrap must only be used behind claddings that meet the requirements of the NZBC, such as those covered by NZBC Acceptable Solution E2/AS1, or claddings covered by a valid BRANZ Appraisal.

12.2 Fast Wrap, when installed in accordance with the Technical Literature and this Appraisal, will assist in the total cladding system's compliance with NZBC Clause E2.

Installation Information

Installation Skill Level Requirements

13.1 Installation must always be carried out in accordance with the Fast Wrap Technical Literature and this Appraisal, by competent tradespersons with an understanding of wall wrap installation.

Wrap Installation

14.1 Fast Wrap must be fixed to all framing members at maximum 300 mm centres with large-head clouts 20 mm long, 6-8 mm staples, self drilling screws or proprietary wrap fixings. The membrane must be pulled taut over the framing before fixing.

14.2 Fast Wrap must be run horizontally and must extend from the upper-side of the top plate to the under-side of the bearers or wall plates supporting ground floor joists, or below bottom plates on concrete slabs. Horizontal laps must be no less than 150 mm wide, with the direction of the lap ensuring that water is shed to the outer face of the membrane. End laps must be made over framing and be no less than 150 mm wide.

14.3 The wall wrap should be run over openings and these left covered until windows and doors are ready to be installed. Openings are formed in the membrane by cutting on a 45 degree diagonal from each corner of the penetration. The flaps of the cut membrane must be folded inside the opening and stapled to the penetration framing. Excess wrap may be cut off flush with the internal face of the wall frame.

14.4 Fast Wrap can be added as a second layer over head flashings in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.7(e).

14.5 When fixing the product in windy conditions, care must be taken due to the large sail area created by wide roll widths.

14.6 Any damaged areas of Fast Wrap, such as tears, holes or gaps around service penetrations, must be repaired. Damaged areas can be repaired by covering with new material lapping the damaged area by at least 150 mm and taping, or by taping small tears.

Inspections

14.7 The Technical Literature must be referred to during the inspection of Fast Wrap installations.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

15.1 The following tests have been carried out on Fast Wrap in accordance with NZBC Acceptable Solution E2/AS1, Table 23: tensile strength, edge-tear resistance and resistance to water vapour transmission in accordance with AS/NZS 4200.1, shrinkage in accordance with AS/NZS 4201.3, resistance to water penetration in accordance with AS/NZS 4201.4, surface water absorbency in accordance with AS/NZS 4201.6, pH of extract in accordance with AS/NZS 1301.421s and air resistance to BS 6538.3. A range of these tests were completed before and after Fast Wrap was exposed to ultra-violet light.

15.2 The flammability index of Fast Wrap has been tested in accordance with AS/NZS 1530.2.

Other Investigations

- 16.1 A durability opinion was given by BRANZ technical experts.
- 16.2 An evaluation of the expected performance of Fast Wrap in direct contact with metal wall cladding has been completed by BRANZ.
- 16.3 Site inspections were carried out by BRANZ to assess methods used for the installation of Fast Wrap.
- 16.4 The marketer's Technical Literature, including installation instructions, has been examined by BRANZ and found to be satisfactory.

Quality

- 17.1 The manufacture of Fast Wrap has not been examined by BRANZ, but details of the methods adopted for quality control and the quality of the materials used, have been obtained and found to be satisfactory.
- 17.2 The quality of supply to the market is the responsibility of Paul Industries.
- 17.3 Building designers are responsible for the design of the building, and for the incorporation of the wall wrap into their design in accordance with the instructions of Paul Industries.
- 17.4 Quality of installation is the responsibility of the installer in accordance with the instructions of Paul Industries.

Sources of Information

- AS 1530.2 - 1993 Test for flammability of materials.
- AS/NZS 1301.421s: 1988 Determination of the pH value of aqueous extracts of paper, board and pulp - cold extraction method.
- AS/NZS 4200.1: 1994 Pliable building membranes and underlays - materials.
- AS/NZS 4201.3: 1994 Pliable building membranes and underlays - Methods of test - Shrinkage.
- AS/NZS 4201.4: 1994 Pliable building membranes and underlays - Methods of test - Resistance to water penetration.
- AS/NZS 4201.6: 1994 Pliable building membranes and underlays - Methods of test - Surface water absorbency.
- BS 6538.3: 1987 Method for determination of air permeance using the Garley apparatus.
- NZS 2295: 2006 Pliable, permeable building underlays.
- NZS 3604: 1999 Timber Framed Buildings.
- NZS 3604: 2011 Timber-Framed Buildings.
- Compliance Document for the New Zealand Building Code External Moisture Clause E2, Department of Building and Housing, Third Edition July 2005.
- New Zealand Building Code Handbook, Department of Building and Housing, Third Edition May 2007.
- The Building Regulations 1992 up to, and including, August 2008 amendment.

Amendment No. 1, dated 3 November 2009.

This Appraisal has been amended to change the cover image and include the Appraisal Holders web address.

Amendment No. 2, dated 1 March 2011.

This Appraisal has been amended to cover the use of Fast Wrap in direct contact with metal based wall cladding.



BRANZ

In the opinion of BRANZ, Fast Wrap Building Wrap is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to Paul Industries, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the technical literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. Paul Industries:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions.
3. Warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
4. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by Paul Industries.
5. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
6. BRANZ provides no certification, guarantee, indemnity or warranty, to Paul Industries or any third party.

For BRANZ

C Preston
Chief Executive

Date of issue: 7 August 2008